

08/04/2025

DECCAN HERALD
Tuesday
April 8, 2025

STATE

KURNOOL-IV TRANSMISSION LIMITED

(100% wholly owned subsidiary of Power Grid Corporation of India Limited)
B-9, Qutab Institutional Area, Katwaria Sarai, New Delhi-110 016

NOTICE

(UNDER SUB-SECTION (2) OF SECTION 15 OF THE ELECTRICITY ACT, 2003)

1. KURNOOL-IV TRANSMISSION LIMITED, having its Registered Office at B-9, QUTAB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI-110016, which is incorporated under the Companies Act, 2013, has made an application before the Central Electricity Regulatory Commission, New Delhi under Sub- Section (1) of Section 15 of the Electricity Act, 2003 for grant of Transmission Licence in respect of the transmission lines, sub-stations and other assets, the details of which are given below:-

S. No.	Name of the Line / Substation (location as per Note)	Line Length as per survey report of BPC/Capacity	Transmission Charges (INR) Million per annum	Schedule COD	Remarks
1.	Establishment of 4x1500 MVA, 765/400 kV and 4x500 MVA, 400/220 kV Kurnool-IV Pooling Station near Kurnool, Andhra Pradesh along with 2x330 MVA (765 kV) bus reactors at Kurnool-IV PS with provision of two (2) sections of 4500 MVA each at 400 kV level and its associated equipments	8000 MVA 660 MVAR (BR) 1140 MVAR (SLR)	6451.06	24 months (24.03.2027)	
2.	Kurnool-IV – Bidar 765 kV D/C line with 330 MVAR SLR (convertible) at both ends on both circuits	375.322 km 660 MVAR (SLR) @ Bidar			
3.	Kurnool-IV – Kurnool-III PS 765 kV D/C line with 240 MVAR SLR (convertible) at Kurnool-IV end on both circuits	127.089 Km			
4.	± 300 MVAR STATCOM at Kurnool-IV PS along with 2x125 MVAR MSR	± 300 MVAR			
5.	Augmentation of 1x1500 MVA, 765/400 kV ICT (3rd) at C'Peta	1500 MVA			
6.	LILo of Vijayawada-Nellore 400 kV D/C line at C'Peta	Loop In: 17.947 Km Loop Out: 18.256 Km			

Note: (i) Locations for elements 1,3,4,5 & 6 are in the state of Andhra Pradesh. While elements 2 is in the state of Telangana, Karnataka & Andhra Pradesh.
(ii) For complete scope please visit <https://www.powergrid.in/subsidiaries>

2. Complete application and other documents filed before the Commission are available on the web site of Power Grid Corporation of India Limited <https://www.powergrid.in/subsidiaries> for access by any person. The application can also be inspected at the office of the Company at C/o ED (TBCB), Power Grid Corporation of India Limited, Saudamini, Plot No.2, Sector -29, Gurgaon 122001 with Sh. A C Sankaraiah, Project Incharge, Kurnool-IV Transmission Limited or Office of the Commission in accordance with the procedure specified by the Commission.

3. Objections or suggestions, if any, be filed before the Secretary, Central Electricity Regulatory Commission, 7th Floor, Tower B, World Trade Centre, Nauroji Nagar, New Delhi- 110029 , with a copy of the objection(s)/suggestion(s) to the applicant or its authorized agent, within 15 days of the publication of the notice in the newspaper.

Place: New Delhi
Date: 08.04.2025

Sh. A C Sankaraiah
Project Incharge,
Kurnool-IV Transmission Limited

A Maharatna PSU

PG/CC/ Notice -218 (TBCB)/Advn-281/24-25 Paramin

08/04/2025

STATE

DECCAN CHRONICLE | VIJAYAWADA | TUESDAY | 8 APRIL 2025

KURNOOL-IV TRANSMISSION LIMITED

(100% wholly owned subsidiary of Power Grid Corporation of India Limited)
B-9, Qutab Institutional Area, Katwarla Sarai, New Delhi-110 016

NOTICE

(UNDER SUB-SECTION (2) OF SECTION 15 OF THE ELECTRICITY ACT, 2003)

1. KURNOOL-IV TRANSMISSION LIMITED, having its Registered Office at B-9, QUTAB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI-110016, which is incorporated under the Companies Act, 2013, has made an application before the Central Electricity Regulatory Commission, New Delhi under Sub- Section (1) of Section 15 of the Electricity Act, 2003 for grant of Transmission Licence in respect of the transmission lines, sub-stations and other assets, the details of which are given below:-

S. No.	Name of the Line / Substation (location as per Note)	Line Length as per survey report of BPC/Capacity	Transmission Charges (INR) Million per annum	Schedule COD	Remarks
1.	Establishment of 4x1500 MVA, 765/400 kV and 4x500 MVA, 400/220 kV Kurnool-IV Pooling Station near Kurnool, Andhra Pradesh along with 2x330 MVA (765 kV) bus reactors at Kurnool-IV PS with provision of two (2) sections of 4500 MVA each at 400 kV level and its associated equipments	8000 MVA 660 MVAR (BR) 1140 MVA (SLR)	6451.06	24 months (24.03.2027)	
2.	Kurnool-IV – Bidar 765 kV D/C line with 330 MVA SLR (convertible) at both ends on both circuits	375.322 km 660 MVAR (SLR) @ Bidar			
3.	Kurnool-IV – Kurnool-III PS 765 kV D/C line with 240 MVA SLR (convertible) at Kurnool-IV end on both circuits	127.089 Km			
4.	± 300 MVA STATCOM at Kurnool-IV PS along with 2x125 MVA MSR	± 300 MVA			
5.	Augmentation of 1x1500 MVA, 765/400 kV ICT (3rd) at C'Peta	1500 MVA			
6.	LILO of Vijayawada-Nellore 400 kV D/C line at C'Peta	Loop In: 17.947 Km Loop Out: 18.256 Km			

Note: (i) Locations for elements 1,3,4,5 & 6 are in the state of Andhra Pradesh. While elements 2 is in the state of Telangana, Karnataka & Andhra Pradesh.
(ii) For complete scope please visit <https://www.powergrid.in/subsidiaries>

2. Complete application and other documents filed before the Commission are available on the web site of Power Grid Corporation of India Limited <https://www.powergrid.in/subsidiaries> for access by any person. The application can also be inspected at the office of the Company at C/o ED (TBCB), Power Grid Corporation of India Limited, Saudamini, Plot No.2, Sector -29, Gurgaon 122001 with Sh. A C Sankaraiah, Project Incharge, Kurnool-IV Transmission Limited or Office of the Commission in accordance with the procedure specified by the Commission.

3. Objections or suggestions, if any, be filed before the Secretary, Central Electricity Regulatory Commission, 7th Floor, Tower B, World Trade Centre, Nauroji Nagar, New Delhi- 110029 , with a copy of the objection(s)/suggestion(s) to the applicant or its authorized agent, within 15 days of the publication of the notice in the newspaper.

Place: New Delhi
Date: 08.04.2025

Sh. A C Sankaraiah
Project Incharge,
Kurnool-IV Transmission Limited

A Maharatna PSU

PG/CC/ Notice -218 (TBCB)/Advt-281/24-25 Paramin